



		Must Be Defined										Options			
		V	1	-											
<u>Down Cable Connection</u>															
7-Pin Amphenol Connector	<b>07</b>														
6 Jaw Meter Base - A Config	<b>6A</b>														
6 Jaw Meter Base - D Config	<b>6D</b>														
6 Jaw Meter Base - E Config	<b>6E</b>														
6 Jaw Meter Base - F Config	<b>6F</b>														
Internal Connecting Terminal Block	<b>NT</b>														
<u>Supply Voltage</u>															
120 VAC	<b>1</b>														
<u>SCADA Communications</u>															
None	<b>0</b>														
Fiber with ST Connectors	<b>F</b>														
Serial with DB-9 Connector	<b>S</b>														
(Phoenix Conn) Serial Direct Hardwired	<b>D</b>														
<b>(Define if using PoE)</b> Ethernet	<b>E</b>														
<u>Temperature Sensor</u>															
None	<b>0</b>														
Temp	<b>T</b>														
<u>Trip Operation Type</u>															
AC Trip	<b>A</b>														
DC Trip	<b>D</b>														
AC and DC Trip	<b>B</b>														
<u>Current Sensing</u>															
None	<b>0</b>														
(0-10V) LPCS	<b>L</b>														
CT	<b>C</b>														
<u>Cap Bank Wye Neutral Sensing</u>															
None	<b>0</b>														
CT	<b>C</b>														
(120V NOM Secondary) PT	<b>P</b>														
<u>Enclosure</u>															
8x8 Carlon with Meter Base	<b>0</b>														
(NMK8V) 8x8 Carlon with Carlon Brackets	<b>3</b>														
(VBK02) 8x8 Carlon with Aluminum Brackets	<b>5</b>														
(NMK12V) 12x14 Carlon with Carlon Brackets	<b>1</b>														
(VBK01) 12x14 Carlon with Aluminum Brackets	<b>2</b>														
<u>Compatible with:</u> DC Trip															
Cooper ECS															
Joslyn VSV	Type 1	<b>1</b>													
ABB PSx5															
Cooper VCS-1S															
Maysteel UltraVac	Type 2	<b>2</b>													
<u>Options - Not Necessarily Used</u>															
(Dash)	-														
<u>Power over Ethernet</u>															
12 VDC	<b>E1</b>														
(Passive) 24 VDC	<b>E2</b>														
48 VDC	<b>E4</b>														
IEEE 802.3af	<b>E0</b>														
<u>Staged Banks</u>															
Configuration 1	<b>21</b>														
Configuration 2	<b>22</b>														