



		Must Be Defined										Options				
		V	3		-											
<u>Down Cable Connection</u>																
8-Pin Amphenol Connector	08															
Internal Connecting Terminal Block	NT															
<u>Supply Voltage</u>																
120 VAC	1															
<u>SCADA Communications</u>																
None	0															
Fiber with ST Connectors	F															
Serial with DB-9 Connector	S															
(Phoenix Conn) Serial Direct Hardwired	D															
(Define if using PoE) Ethernet	E															
<u>Temperature Sensor</u>																
None	0															
Temp	T															
<u>Battery Backup</u>																
None	0															
(12V DC) Battery & Charger	1															
<u>Current Sensing</u>																
None	0															
(0-10V) LPCS	L															
CT	C															
<u>Cap Bank Wye Neutral Sensing</u>																
None	0															
CT	C															
(120V NOM Secondary) PT	P															
<u>Enclosure</u>																
(NMK12V) 12x14 Carlon w/ Carlon Brackets	1															
(VBK01) 12x14 Carlon w/ Aluminum Brackets	2															
<u>Switch Type *</u>																
Cooper ECS	00															
Joslyn VSV	01															
ABB PSx5	02															
Cooper VCS-1S	03															
Maysteel UltraVac	04															
Siemens 3AD	05															
<u>Frequency</u>																
50 Hz	5															
60 Hz	6															
<u>Define For Previous Spec, Not Necessarily Used</u>																
(Dash)	-															
<u>Radio Part Number</u>																
Freewave FGR2-PE-U	R1															
Freewave FGR09CSU	R2															
GE MDS SDx	R3															
(User Specified Radio)	R0															
<u>Isolation Power Supply</u>																
12 VDC	E1															
(Radio or PoE) 24 VDC	E2															
48 VDC	E4															
IEEE 802.3af	E0															

* ZVC Model Variants ONLY
Contact Valquest Systems for compatible part numbers